

| School Site | Sample #1 | Sample #2 | Sample #3 |
|------------------------|-----------|-----------|-----------|
| Adams | <5 PPB | <5 PPB | |
| Arthur | <5 PPB | <5 PPB | |
| Bodine | <5 PPB | <5 PPB | |
| Buchanan | <5 PPB | <5 PPB | |
| Capitol Hill ES | <5 PPB | <5 PPB | |
| Capitol Hill HS | <5 PPB | <5 PPB | <5 PPB |
| Cesar Chavez | <5 PPB | <5 PPB | |
| Classen SAS HS | <5 PPB | <5 PPB | <5 PPB |
| Cleveland | <5 PPB | <5 PPB | |
| Coolidge | <5 PPB | <5 PPB | |
| Douglass HS | <5 PPB | <5 PPB | <5 PPB |
| Edwards | <5 PPB | <5 PPB | |
| Eugene Field | <5 PPB | <5 PPB | |
| F.D. Moon | <5 PPB | <5 PPB | |
| Fillmore | <5 PPB | <5 PPB | |
| Gatewood | <5 PPB | <5 PPB | |
| Hawthorne | <5 PPB | <5 PPB | |
| Heronville | <5 PPB | <5 PPB | |
| Jackson ES | <5 PPB | <5 PPB | |
| Lee | <5 PPB | <5 PPB | |
| Linwood | <5 PPB | <5 PPB | |
| Mark Twain | <5 PPB | <5 PPB | |
| Martin Luther King, Jr | <5 PPB | <5 PPB | |
| N.W. Classen HS | <5 PPB | <5 PPB | <5 PPB |
| Northeast HS | <5 PPB | <5 PPB | <5 PPB |
| Parks | <5 PPB | <5 PPB | |
| Pierce | <5 PPB | <5 PPB | |
| Rancho Village | <5 PPB | <5 PPB | |
| Rockwood | <5 PPB | <5 PPB | |
| Roosevelt MS | <5 PPB | <5 PPB | <5 PPB |
| Southeast HS | <5 PPB | <5 PPB | <5 PPB |
| Stand Watie | <5 PPB | <5 PPB | |
| Taft MS | <5 PPB | <5 PPB | <5 PPB |
| U.S. Grant HS | <5 PPB | <5 PPB | <5 PPB |
| Van Buren | <5 PPB | <5 PPB | |
| Westwood | <5 PPB | <5 PPB | |
| Wheeler | <5 PPB | <5 PPB | |

EPA Action level of 0.015 mg/L (15 ppb) for lead. Laboratory is not able to detect below 5 Parts Per Billion (PPB). All Sites tested were below detectable limits.